



**NOTES:**

1. ALL PRIVATE UTILITIES TO BE LOCATED A MINIMUM OF 3' BEHIND THE CURB.
2. MINIMUM COVER FOR PRIVATE UTILITIES IS 30".
3. CONTACT RESPECTIVE PRIVATE UTILITY COMPANY FOR SPACING REQUIREMENTS WITH OTHER PRIVATE UTILITIES.
4. MAINTAIN A MINIMUM LATERAL CLEARANCE OF 7.5' BETWEEN WATER AND POWER.
5. AN INCREASE IN UTILITY SEPARATION MAY BE REQUIRED IF ANY UTILITY IS OVER 10' DEEP OR OVER 24" IN DIAMETER.
6. ANY VARIATIONS FROM THIS DESIGN MUST BE APPROVED BY THE CITY ENGINEER.

|   |           |         |
|---|-----------|---------|
| CITY OF ALBANY, OREGON<br>PUBLIC WORKS DEPARTMENT |           |         |
| UNDERGROUND UTILITY<br>LOCATIONS                  |           |         |
| NO SCALE  | JULY 2005 | NO. 201 |