



NOTES:

1. CONCRETE SHALL HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 4000 PSI.
2. CURB AND GUTTER SHALL BE CONSTRUCTED INDEPENDENTLY, AND SEPARATED BY A COLD JOINT, FROM ALL ADJACENT CONCRETE CONSTRUCTION; INCLUDING SIDEWALKS AND DRIVEWAY RAMPS.
3. PROVIDE CONTRACTION JOINT AT MIDPOINT OF DRIVEWAY IF DRIVEWAY IS 16' WIDE OR GREATER.
4. RESIDENTIAL DRIVEWAY WIDTH 10' - 24', COMMERCIAL DRIVEWAY WIDTH PER DEVELOPMENT CODE, ARTICLE 12, CHAPTER 12.100
5. NEW DRIVEWAY ACCESS CONSTRUCTION IN AN EXISTING CURB SHALL BE CONSTRUCTED WITH THE USE OF HORIZONTAL CONCRETE SAWCUTTING EQUIPMENT. SEE 306.02.07B.

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
RESIDENTIAL AND COMMERCIAL DRIVEWAYS WITH SETBACK SIDEWALK		
NO SCALE	JANUARY 2011	NO. 308