



6" CONC. FOR RESIDENTIAL
 8" CONC. FOR COMMERCIAL
 10" CONC. FOR ALLEY APPROACHES

3" OF COMPACTED
 CRUSHED AGGREGATE

SECTION

NOTES:

1. CONCRETE SHALL HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 4000 PSI.
2. CURB AND GUTTER SHALL BE CONSTRUCTED INDEPENDENTLY, AND SEPARATED BY A COLD JOINT, FROM ALL ADJACENT CONCRETE CONSTRUCTION; INCLUDING SIDEWALKS AND DRIVEWAY RAMPS.
3. PROVIDE CONTRACTION JOINT AT MIDPOINT OF DRIVEWAY IF DRIVEWAY WIDTH IS 16' OR GREATER.
4. RESIDENTIAL DRIVEWAY WIDTH 10' - 24'. COMMERCIAL DRIVEWAY WIDTH PER DEVELOPMENT CODE, ARTICLE 12, CHAPTER 12.100.
5. NEW DRIVEWAY ACCESS CONSTRUCTION IN AN EXISTING CURB SHALL BE CONSTRUCTED WITH THE USE OF HORIZONTAL CONCRETE SAWCUTTING EQUIPMENT. SEE 306.02.07B.

**CITY OF ALBANY, OREGON
 PUBLIC WORKS DEPARTMENT**

**RESIDENTIAL AND COMMERCIAL
 DRIVEWAYS WITH
 CURB SIDE SIDEWALK**

NO SCALE	OCTOBER 2013	NO. 309A
----------	--------------	----------