



NOTES:

1. MANHOLE BASES, BARREL SECTIONS, CONCENTRIC CONES, AND GRADE RINGS SHALL BE CONSTRUCTED OF PRECAST REINFORCED CONCRETE, CONFORMING TO ASTM C478.
2. 48" MANHOLE DETAILS ARE FOR PIPES 24" OR SMALLER. CONFIGURATION DETAILS FOR MANHOLES WITH LARGER PIPES WILL BE DETERMINED BY THE CITY ENGINEER.
3. MAXIMUM DISTANCE BETWEEN THE TOP OF THE CONE SECTION AND FINAL SURFACE GRADE SHALL NOT EXCEED 15".
4. PROVIDE FOR A PIPE JOINT WITHIN 24" OF THE MANHOLE WHEN INSTALLING RIGID PIPE.
5. NO INTERIOR GROUTING IS ALLOWED.
6. MINIMUM 6" CONCRETE AT INTERIOR OF MANHOLE REQUIRED BETWEEN PIPE OPENINGS AND/OR EDGES OF BARREL SECTIONS.

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
STANDARD PRECAST MANHOLE		
NO SCALE	FEBRUARY 2024	NO. 401