



SECTION A-A

NOTES:

1. VALLEY GUTTER SHALL NOT BE USED WITHOUT APPROVAL OF THE CITY ENGINEER.
2. ALL CONCRETE SHALL HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 4000 PSI.
3. PROVIDE GUTTER CONTRACTION JOINTS AT 15' O.C. MAX.

CITY OF ALBANY, OREGON  
PUBLIC WORKS DEPARTMENT

VALLEY GUTTER DETAIL

NO SCALE

MAY 1998

NO. 305