

ORDINANCE NO. 4857

AN ORDINANCE AMENDING ALBANY MUNICIPAL CODE 17.28.150, UNIFORM FIRE CODE, AMENDMENTS.

WHEREAS, Ordinance 4757 adopted certain amendments to the Uniform Fire Code, and WHEREAS, from time to time, revisions to those amendments become necessary.

NOW, THEREFORE, THE PEOPLE OF THE CITY OF ALBANY DO ORDAIN AS FOLLOWS:

Section 1: Albany Municipal Code 17.28,150, Uniform Fire Code, Amendments is hereby amended to read as follows:


XII. Article 79 Section 79.501. Storage of Class I and Class II liquids in outside aboveground tanks is limited to ~~2,000-gallons~~ **6,000 gallons per tank maximum and 12,000 gallons maximum aggregate** within the City limits, except as shall be allowed by the Chief of the Fire Department.

EXCEPTION: Liquid petroleum tanks that do not exceed 2,000 gallons water capacity. See Section 32.105(a).

Passed by Council March 22, 1989

Approved by the Mayor: March 23, 1989

Effective Date: April 21, 1989



Mayor

ATTEST:



City Recorder