

SELECT ONE OPTION FROM EACH OF THE SECTIONS/ TABLES:

PRESCRIPTIVE ENVELOPE REQUIREMENTS^a TABLE N1101.1(1)

BUILDING COMPONENT	STANDARD BASE CASE		LOG HOMES ONLY	
	Required Performance	Equiv. Value ^b	Required Performance	Equiv. Value ^b
Wall insulation-above grade	U-0.060	R-21 ^c	Note d	Note d
Wall insulation-below grade ^e	F-0.565	R-15	F-0.565	R-15
Flat ceilings ^f	U-0.031	R-38	U-0.025	R-49
Vaulted ceilings ^g	U-0.042	R-38 ^g	U-0.027	R-38A ^h
Underfloors	U-0.028	R-30	U-0.028	R-30
Slab edge perimeter	F-0.520	R-15	F-0.520	R-15
Heated slab interior ⁱ	n/a	R-10	n/a	R-10
Windows ^j	U-0.35	U-0.35	U-0.35	U-0.35
Window area limitation ^k	n/a	n/a	n/a	n/a
Skylights ^l	U-0.60	U-0.60	U-0.60	U-0.60
Exterior doors ^m	U-0.20	U-0.20	U-0.54	U-0.54
Exterior doors w/ > 2.5 ft ² glazing ⁿ	U-0.40	U-0.40	U-0.40	U-0.40
Forced air duct insulation	n/a	R-8	n/a	R-8

For SI: 1 inch = 25.4 mm, 1 square foot = 0.0929 m², 1 degree = 0.0175 rad.

- a. As allowed in Section N1104.1, thermal performance of a component may be adjusted provided that overall heat loss does not exceed the total resulting from conformance to the required *U*-value standards. Calculations to document equivalent heat loss shall be performed using the procedure and approved *U*-values contained in Table N1104.1(1).
- b. *R*-values used in this table are nominal for the insulation only in standard wood framed construction and not for the entire assembly.
- c. Wall insulation requirements apply to all exterior wood framed, concrete or masonry walls that are above grade. This includes cripple walls and rim joist areas. R-19 Advanced Frame or 2 × 4 wall with rigid insulation may be substituted if total nominal insulation *R*-value is 18.5 or greater.
- d. The wall component shall be a minimum solid log or timber wall thickness of 3.5 inches (90 mm).
- e. Below-grade wood, concrete or masonry walls include all walls that are below grade and do not include those portions of such wall that extend more than 24 inches (609.6 mm) above grade.
- f. Insulation levels for ceilings that have limited attic/rafter depth such as dormers, bay windows or similar architectural features totaling not more than 150 square feet (13.9 m²) in area may be reduced to not less than R-21. When reduced, the cavity shall be filled (except for required ventilation spaces).
- g. The maximum vaulted ceiling surface area shall not be greater than 50 percent of the total heated space floor area unless area has a *U*-factor no greater than U-0.031. The *U*-factor of 0.042 is representative of a vaulted scissor truss. A 10-inch (254mm) deep rafter vaulted ceiling with R-30 insulation is U-0.033 and complies with this requirement, not to exceed 50 percent of the total heated space floor area.
- h. A = Advanced frame construction, which shall provide full required insulating value to the outside of exterior walls.
- i. Heated slab interior applies to concrete slab floors (both on and below grade) that incorporate a radiant heating system within the slab. Insulation shall be installed underneath the entire slab.
- j. Sliding glass doors shall comply with window performance requirements. Windows exempt from testing in accordance with Section NF1111.2, Item 3 shall comply with window performance requirements if constructed with thermal break aluminum or wood, or vinyl, or fiberglass frames and double-pane glazing with low-emissivity coatings of 0.10 or less. Buildings designed to incorporate passive solar elements may include glazing with a *U*-factor greater than 0.35 by using Table N1104.1(1) to demonstrate equivalence to building envelope requirements.
- k. Reduced window area may not be used as a trade-off criterion for thermal performance of any component.
- l. Skylight area installed at 2 percent or less of total heated space floor area shall be deemed to satisfy this requirement with vinyl, wood or thermally broken aluminum frames and double-pane glazing with low-emissivity coatings. Skylight *U*-factor is tested in the 20 degree (0.35 rad) overhead plane in accordance with NFRC standards.
- m. A maximum of 28 square feet (2.6 m²) of exterior door area per dwelling unit can have a *U*-factor of 0.54 or less.
- n. Glazing that is either double pane with low-e coating on one surface, or triple pane shall be deemed to comply with this U-0.40 requirement.

ENVELOPE ENHANCEMENT MEASURES - TABLE N1101.1(2) Revised

Envelope Enhancement Measure (Select One)	1	High efficiency walls & windows: Exterior walls – U-0.047 / R-19+5 (insulation sheathing) / SIPS, and Windows – Max 15% of conditioned area; or Windows-U-0.30
	2	High efficiency envelope: Exterior walls – U-0.058 / R-21 Intermediate framing, and Vaulted ceilings – U-0.033 / R-30A ^{d,e} , and Flat ceilings – U-0.025 / R-49, and Framed floors – U-0.025 / R-38, and Windows – U-0.30; and Doors- All doors U-0.20, or Additional 15 percent of permanently installed lighting fixtures as high-efficacy lamps or Conservation Measure D and E.
	3	High efficiency ceiling, windows & duct sealing: (Cannot be used with Conservation Measure E) Vaulted ceilings – U-0.033 / R-30A ^{d,e} , and Flat ceilings – U-0.025 / R-49, and Windows-U-0.30 Windows- U-0.30, and Performance tested duct systems ^b
	4	High efficiency thermal envelope UA: Proposed UA is 15% lower than the Code UA when calculated in Table N1104.1(1)
	5	Building tightness testing, ventilation & duct sealing (Cannot be used with Measure E): A mechanical exhaust, supply, or combination system providing whole-building ventilation rates specified in Table 1101.1(3), or ASHRAE 62.2, and The dwelling shall be tested with a blower door and found to exhibit no more than: 1. 6.0 air changes per hour ^f , and Performance tested duct systems ^b
	6	Ducted HVAC systems within conditioned space: (Cannot be used with Conservation Measure B or C) All ducts and air handler are contained within building envelope ⁱ

CONSERVATION MEASURES - TABLE N1101.1(2)

Conservation Measure (Select One)	A	High efficiency HVAC system: Gas-fired furnace or boiler with minimum AFUE of 90% a, or Air-source heat pump with minimum HSPF of 8.5 or Closed-loop ground source heat pump with minimum COP of 3.0
	B	Ducted HVAC systems within conditioned space: All ducts and air handler are contained within building envelope ⁱ
	C	Ductless heat pump: Replace electric resistance heating in at least the primary zone of dwelling with at least one ductless mini-split heat pump having a minimum HSPF of 8.5. Unit shall not have integrated backup resistance heat, and the unit (or units, if more than one is installed in the dwelling) shall be sized to have capacity to meet the entire dwelling design heat loss rate at outdoor design temperature condition. Conventional electric resistance heating may be provided for any secondary zones in the dwelling. A packaged terminal heat pump (PTHP) with comparable efficiency ratings may be used when no supplemental zonal heaters are installed in the building and integrated backup resistant heat is allowed in a PTHP
	D	High efficiency water heating & lighting: Natural gas/propane, on-demand water heating with min EF of 0.80, and A minimum 75 percent of permanently installed lighting fixtures as CFL or linear fluorescent or a min efficacy of 40 lumens per watt as specified in Section N1107.2c
	E	Energy management device & duct sealing: Whole building energy management device that is capable of monitoring or controlling energy consumption, and Performance tested duct systems ^b , and A minimum 75 percent of permanently installed lighting fixtures as high-efficacy lamps.
	F	Solar photovoltaic: Minimum 1 watt/sq ft conditioned floor space ^g
	G	Solar water heating: Minimum of 40 ft ² of gross collector area ^h

For SI: 1 square foot = 0.093 m², 1 watt per square foot = 10.8 W/m².

- a. Furnaces located within the building envelope shall have sealed combustion air installed. Combustion air shall be ducted directly from the outdoors.
- b. Documentation of Performance Tested Ductwork shall be submitted to the building official upon completion of work. This work shall be performed by a contractor certified by the Oregon Department of Energy's (ODOE) Residential Energy Tax Credit program and documentation shall be provided that work demonstrates conformance to ODOE duct performance standards.
- c. Section N1107.2 requires 50 percent of permanently installed lighting fixtures to contain high efficacy lamps. Each of these additional measures adds an additional percent to the Section N1107.2 requirement.
- d. A = advanced frame construction, which shall provide full required ceiling insulation value to the outside of exterior walls.
- e. The maximum vaulted ceiling surface area shall not be greater than 50 percent of the total heated space floor area unless vaulted area has a U-factor no greater than U-0.026.
- f. Building tightness test shall be conducted with a blower door depressurizing the dwelling 50 Pascal's from ambient conditions. Documentation of blower door test shall be submitted to the Building Official upon completion of work.
- g. Solar electric system size shall include documentation indicating that Total Solar Resource Fraction is not less than 75 percent.
- h. Solar water heating panels shall be Solar Rating and Certification Corporation (SRCC) Standard OG-300 certified and labeled, with documentation indicating that Total Solar Resource Fraction is not less than 75 percent.
- i. A total of 5 percent of an HVAC systems ductwork shall be permitted to be located outside of the conditioned space. Ducts located outside the conditioned space shall have insulation installed as required in this code.

VENTILATION AIR REQUIREMENTS, cfm - TABLE N1101.1(3)

FLOOR AREA (FT ²)	BEDROOMS				
	0-1	2-3	4-5	6-7	>7
<1500	30	45	60	75	90
1501-3000	45	60	75	90	105
3001-4500	60	75	90	105	120
4501-6000	75	90	105	120	135
6001-7500	90	105	120	135	150
>7501	105	120	135	160	185

For SI: 1 square foot = 0.0929 m².

SMALL ADDITION ADDITIONAL MEASURES (Select One) – TABLE N1101.3

1	Increase the ceiling insulation of the existing portion of the home as specified in Table N1101.2.
2	Replace all existing single-pane wood or aluminum window to the <i>U</i> -value as specified in Table N1101.2.
3	Insulate the floor system as specified in Table N1101.2 & install 50 percent of permanently installed lighting fixtures as CFL or linear fluorescent or a min. efficacy of 40 lumens per watt as specified in Section N1107.2.
4	Test the entire dwelling with a blower door and exhibit no more than 7.0 air changes per hour @ 50 Pascals.
5	Seal and performance test the duct system.
6	Replace existing 78 percent AFUE or less gas furnace with a 92 percent AFUE or greater system.
7	Replace existing electric radiant space heaters with a ductless mini split system with a minimum HSPF of 8.5
8	Replace existing electric forced air furnace with an air source heat pump with a minimum HSPF of 8.5.
9	Replace existing water heater for a natural gas/propane water heater with a minimum EF of 0.67.
10	Install a solar water heating system with a minimum of 40 ft ² of gross collector area.