



COMMUNITY DEVELOPMENT DEPARTMENT

Planning Division
P.O. Box 490
333 Broadalbin Street SW
Albany, OR 97321
Phone (541) 917-7550
Fax (541) 917-7598
www.cityofalbany.net

Site Plan Review

Checklist & Review Criteria

INFORMATION AND INSTRUCTIONS:

- Filing Fees (*subject to change every July 1*): staff will contact you for payment after submittal.
 - Change of Use, Temporary or Minor Developments: \$133¹
 - Manufactured Home Parks: \$2,426 plus \$20 per space
 - Modify Existing Development²: \$1,750
 - New Parking Areas or Expansions > 1,000 sq.ft.: \$990
 - New Construction: \$2,561 plus 0.15% (0.0015) of construction value³ over \$150,000
 - If Traffic Report Required: Additional fee of \$673
 - If Design Standards Apply (Albany Development Code (ADC) Article 8): Additional fee of \$295
- Construction Cost: _____
- 1) *Applies to temporary businesses operating 31 to 120 days, temporary subdivision sales offices, and other minor developments not exempt from Site Plan Review or specified herein.*
 - 2) *Additions or expansions > 2,000 sq.ft. or 25% of existing building area, whichever is greater, allowed use or expansions that require 3 or more parking spaces, add loading areas, or change site circulation or access. (See ADC 2.430.)*
 - 3) *This valuation is composed of the estimated cost of all improvements to the land related to the proposed site plan review project, but not the cost of the land itself. Building valuation is computed either from the Building Valuation Table used by the City of Albany's Building Division, or an actual construction bid submitted by the applicant. If the two valuations are different, the highest valuation will prevail. Land improvements include, but are not limited to, patios, decks, sidewalks, parking areas, and landscaping.*
- All plans and drawings must be to scale, and review criteria responses should be provided as specified in this checklist.
 - Email all materials to eplans@cityofalbany.net. Please call 541-917-7550 if you need assistance.
 - Depending on the complexity of the project, paper copies of the application may be required.
 - Before submitting your application, please check the following list to verify you are not missing essential information. An incomplete application will delay the review process.

SITE PLAN REVIEW SUBMITTAL CHECKLIST

PLANNING APPLICATION FORM WITH AUTHORIZING SIGNATURES

NEIGHBORHOOD MEETING SUMMARY (If required)

REVIEW CRITERIA AND DEVELOPMENT STANDARDS RESPONSES

On a separate sheets of paper, prepare detailed written responses, using factual statements (called findings of fact), to explain how the proposed Site Plan complies with each of the following review criteria [ADC 2.450]. Each criterion must have at least one finding of fact and conclusion statement. (See example on page 9.)

1. Public utilities can accommodate the proposed development.
2. The proposed post-construction stormwater quality facilities (private and/or public) can accommodate the proposed development, consistent with Title 12 of the Albany Municipal Code.
3. The transportation system can safely and adequately accommodate the proposed development.
4. Parking areas and entrance-exit points are designed to facilitate traffic and pedestrian safety and avoid congestion.
5. The design and operating characteristics of the proposed development are reasonably compatible with surrounding development and land uses, and any negative impacts have been sufficiently minimized.
6. Activities and developments within special purpose districts must comply with the regulations described in Articles 4 (Airport Approach), 6 (Natural Resources), and 7 (Historic), as applicable.
7. The site is in compliance with prior land use approvals.
8. Sites that have lost their nonconforming status must be brought into compliance, and may be brought into compliance incrementally in accordance with Section 2.370.

In addition to the Site Plan review criteria, the proposed development must meet all applicable standards found in the ADC. Include findings for each the following applicable Articles of the ADC:

1. The proposed project meets applicable development standards of the appropriate zoning category: Article 3 – Residential; Article 4 – Commercial and Industrial; or Article 5 – Mixed Use Village Center.
2. Design Standards; multiple-family, commercial, or telecommunication facility projects must meet applicable design standards found in Article 8. You must address each standard with findings.
3. The proposed project meets applicable off-street parking, landscaping, tree felling, buffering and screening, and environmental standards found in Article 9.
4. Manufactured home park projects must meet applicable standards found in Article 10.
5. If the project is a CLUSTER DEVELOPMENT, attach written findings of fact that demonstrate how this project meets ADC 11.400 through 11.510.

The approval authority may designate conditions in order to assure conformance with applicable review criteria and development standards.

SITE PLAN. Refer to pages 4 – 5 for information that needs to be included on the Site Plan.

ELEVATION DRAWINGS. Fully dimensioned drawings of each elevation of each building. Include building height, materials, and colors to be used.

FLOOR PLAN DRAWINGS. Floor plans shall include dimensions and square footages.

- CONCEPTUAL LANDSCAPE AND IRRIGATION PLANS.** The Site Plan may show locations where landscaping will be provided, including any vegetated post-construction stormwater quality facilities. Before occupancy or final inspection of the development, a final landscape plan must be submitted for review and approval. That plan must include a legend that indicates the number, size, spacing, and botanical and common names of all proposed plants.
- PUBLIC UTILITY PLANS.** Submit full-sized copies of preliminary water, sewer and storm sewer plans and systems. These plans must provide enough information to enable the City Engineer to determine that the proposed development is feasible, but are not required to be detailed construction level documents. The City's Engineering Standards, while not land use criteria, may be used, in whole or in part, by the City Engineer to determine the feasibility of a proposed plan.
 - Preliminary Water Plans** **Preliminary Sanitary Sewer Plans**
 - Preliminary Storm Sewer Plans.** Include detention calculations that demonstrate that the proposed detention facility is correctly sized and show how the Storm Drain Control structure will function.

OTHER PERMITS, APPLICATIONS, PLANS, OR REPORTS THAT MAY BE REQUIRED:

- Floodplain Development Permit.** If any of the property is within the Floodplain Development (/FP) overlay, refer to ADC Sections 6.070-6.125 to determine if the Floodplain Development standards apply and if a Floodplain Development Permit is required. **(Fee depends on level of review.)**
- Geotechnical Hillside Development Report.** If any of the property is within this Hillside Development (/HD) overlay, refer to ADC Sections 6.170-6.230 to determine if Hillside Development standards apply. If applicable, attach written findings of fact that demonstrate how this project meets these standards; and provide a geotechnical report on the site. **(Additional fee applies)**
- Natural Resources Impact Review.** If any of the property is within one of Albany's Significant Natural Resource (/SW, /RC, /HA) overlay districts, refer to ADC Sections 6.290-6.300 to determine if a Natural Resource Impact Review may be required. **(Additional fee applies.)**
- Mitigation Plan.** If the project is proposed within any of Albany's Significant Natural Resources overlay districts, a mitigation plan may be required. See ADC Sections 6.400 -6.410. **(Additional fee applies.)**
- Historic Review.** If any property is within a Historic Overlay District or contains a Local Historic Inventory Resource, please refer to Article 7 to determine if historic review is required.

SUPPLEMENTAL APPLICATION INFORMATION

Gross land area of the site to be developed _____

Net land area (gross land minus land to be dedicated to the public) _____

Describe and show on the site plan the location of any existing structures, private wells, septic tanks, drain fields located on the site and indicate whether or not they will remain: _____

Current use(s) of the property _____

Site Zoning: _____ Comprehensive Plan designation: _____

Existing uses and zoning of properties adjacent to the site (including across the street, if applicable):

	<u>Current Uses</u>	<u>Zoning</u>
North	_____	_____
South	_____	_____
East	_____	_____
West	_____	_____

Lot Coverage: Percent lot coverage allowed: _____ Proposed lot coverage percent: _____
 Net land area of the site: _____ Square footage of all building pads: _____
 Square footage of all parking/access areas: _____

Parking Calculations. Indicate the square footage of each use within the proposed structure(s) and amount of parking provided for each use. Refer to ADC Article 9 for parking standards.

Number of bicycle parking spaces required and provided [see ADC Section 9.120(13)]: _____

- Multiple-family projects only: Fill out the Supplemental Information sheet on page 8.
- Is there a phasing plan? _____ **If yes**, indicate how many phases here and clearly outline and label the boundaries of the phases on the site plan. Number of Phases: _____
- Are you applying the Cluster Development overlay district provisions to this project? _____
If yes, attach written findings of fact that demonstrate how this project meets Sections 11.400 through 11.510 of the ADC.

FIRE DEPARTMENT SUPPLEMENTARY QUESTIONNAIRE

1. Does the business plan to **STORE** hazardous materials? Yes ____ No ____
2. Does the business plan to **USE** hazardous materials? Yes ____ No ____
3. Does the business **GENERATE** hazardous materials or hazardous waste? Yes ____ No ____
4. Is the business currently reporting hazardous substances to the State Fire Marshal's Office? Yes ____ No ____

NOTE: Hazardous materials are materials that pose a potential threat to fire and life safety. Examples include paints, solvents, compressed gases, pesticides, poisons, gasoline, propane and laboratory chemicals. Please call the Albany Fire Marshal if you have questions about this section. 541-917-7700.

SITE PLAN REQUIREMENTS

The Site Plan must be labeled as such and label and show the following information. If any listed item below is not provided, please include a written explanation why it should not be applicable to this development.

- Existing address (if any), section, township, range, and legal description sufficient to define the location and boundaries of the site
- Names and addresses of the property owner(s), applicant(s), developer(s), surveyor and engineer, as applicable

- Date plan was drafted and a north arrow
- Scale of the plan. (Use 1 inch = 20 feet, unless otherwise approved by Planning staff. For parcels over 100 acres, use 1 inch = 100 feet.) The plan must be clear, measurable and fully dimensioned.
- Total gross and net land areas of the entire site. ("Net" is minus the square footage of any land proposed for dedication to the public, not including easements.)
- Percentage of the site covered by existing and proposed structures and paved areas. Clearly identify the boundaries and total square footage of all new and/or replaced impervious surfaces.
- Lengths of all existing property lines of the development site
- Zoning designations and boundaries, property boundaries, land uses, and approximate building locations of all adjacent properties
- Area and square footage of any land to be dedicated to the public; include its intended purpose (e.g. right-of-way, parkland, conservation easement, etc.)
- Locations and construction/surface type of all *existing and proposed* driveways
- Locations of all *existing and proposed* structures, wells, septic tanks and drain fields, the distances between them and the existing property lines and each other. Indicate what is to be removed, relocated, and/or retained. If relocated on the site, show and label the new location.
- Locations of all public improvements to be constructed as part of the development of the site (e.g., streets, sidewalks, and utilities)
- Locations and sizes of all *existing and proposed* public sewer and water mains and private service lines from the main to the site; culverts, ditches, and drain pipes, and electric, gas and telephone conduits, including those on site, on adjacent property, and within adjacent rights-of-way. Include invert elevations of sewer lines at points of proposed connections.
- All existing natural drainage patterns, flow arrows showing existing and proposed drainage patterns and existing and proposed swales, ditches, or other drainage ways
- Location, size, type, and capacity of the existing and proposed drainage system including pipe size, slope, and detention facilities. Show existing and proposed finished grade elevations at collection points and property lines. Include the location, size, type and capacity of the downstream drainage system that would serve the proposed development. Also provide any supporting calculations.
- Location, size, type and capacity of all existing and proposed post-construction stormwater quality facilities. Clearly identify all impervious surfaces and contributing areas draining to each facility.
- Locations, widths, and names of all *existing or platted* adjacent public streets, alleys, sidewalks, planter strips, curbs, and other public rights-of-way or uses, railroad rights-of-way, and other important features such as City boundary lines.
- Locations, widths, names, approximate radii or curves, and the relationship of all streets to any proposed streets shown on any City approved plan or proposed with this application.
- Locations, dimensions, ownership, and purpose of all *existing and proposed* easements on the site and on adjacent properties.
- Existing and proposed* contour (topography) lines drawn at one-foot intervals, or at a larger interval if approved by the City Engineer. Indicate the elevations of all control points used to determine the contours. Contours must be related to City of Albany data. See the Engineering Division for data.
- Show the typical cross sections at adjacent property boundaries showing pre-and post-development conditions and clearly identify any changes in elevation at the property line not captured in the typical section.

- Locations and species of trees with individual trunks, or multiple trunks that when combined, are larger than 25 inches in circumference measured at 4½ feet above mean ground level from the base of the trunk. To obtain the circumference of a tree with multiple trunks, add the individual trunks circumferences, which are greater than 6 inches in circumference. Identify any trees proposed for protection and the method of protection. Indicate which, if any, you propose to remove. (A tree felling application may also be required. See ADC 9.205 for tree felling regulations.)
- Locations and dimensions of all delivery and loading areas
- Locations and dimensions of all parking and circulation areas
- Location and dimensions of all vision clearance areas per ADC 12.180
- Locations and dimensions of all trash disposal areas. Include elevation drawing of trash enclosure
- Locations of all proposed signs. (Sign permits are issued separately from this review.)
- Location, design, and illumination detail of proposed site and building lighting
- Location and type of proposed pedestrian amenities and common areas (when applicable)
- Location and design drawings of all proposed utility vaults and mailboxes

Additional plan information. The following may not apply to every site. Please label and show all applicable information on the proposed site plan. *Write "NA" in the box and attach a short explanation as to why it does not apply to this development proposal.*

- Width, direction, and flow of all watercourses on the site
- Areas within the 100-year floodplain and other areas subject to inundation or storm water overflow, with approximate high-water elevation. State the base flood elevation (BFE); label and show the floodplain boundary on the map.
- Location of the following significant natural resources: 1) significant wetlands and waterways identified on the city's Significant Wetland and Waterway overlay district; 2) significant riparian corridors on the city's Riparian Inventory; 3) significant wildlife habitat, if known; 4) existing channels as shown on the most current version of the Albany Storm Water Master Plan; and 5) slopes greater than 12 percent.
- Location of the following natural features: 1) all jurisdictional and non-significant wetlands identified on the city's Local Wetlands Inventory (see also Comprehensive Plan Plate 6) and National Wetland Inventory; 2) wooded areas with 5 or more trees over 8 inches in diameter measured 4½ feet from the ground; and 3) springs.
- Location of airport height restrictions
- Location of Willamette Greenway and the top of the bank
- Location of historic districts, structures, and sites on the City's adopted Local Historic Inventory, including individually designated National Register Historic Landmarks and archaeological sites.

Note: Some properties may have covenants or restrictions, which are private contracts between neighboring landowners. These frequently relate to density, minimum setbacks, or size and heights of structures. While these covenants and restrictions do not constitute a criterion for a City land use decision, they may raise a significant issue with regard to the City's land use criteria. It is the responsibility of the applicant to investigate private covenants or restrictions.

SUPPLEMENTAL INFORMATION FOR MULTIPLE FAMILY DEVELOPMENTS

(Additions to existing development or completely new development)

1. **Net land area** (gross land minus public dedications/undevelopable areas like water bodies and open spaces):

Gross land area of the site: _____ sq. ft.

Right-of-way or public dedications and undevelopable areas: _____ sq. ft.

= _____ NET sq. ft. of land area

2. **Lot coverage:** maximum allowable by the ADC for this zone is _____%. [See Article 3, Table 1.] Lot coverage includes parking, driveway and building pad areas; it does not include patios or internal pedestrian walkways. **Analysis for this application:**

All building foundation coverage is _____ sq. ft. = _____ % of total net site

All parking and driveway areas are _____ sq. ft. = _____ % of total net site

3. **Density calculation analysis for the _____ Zoning District.**
[See ADC, Section 3.190, Table 1 for the minimum land area required per dwelling unit.]

_____ Single-family dwelling units @ _____ sq. ft. per unit = _____ sq. ft.

_____ Duplex units @ _____ sq. ft. per duplex = _____ sq. ft.

_____ Two or more attached single-family @ _____ sq. ft. per unit = _____ sq. ft.

_____ Three or more 1-bedroom units @ _____ sq. ft. per unit = _____ sq. ft.

_____ Three or more 2- 3-bedroom units @ _____ sq. ft. per unit = _____ sq. ft.

Total = _____ sq. ft. (This total should be no greater than **net land area in 1** above.)

If the net land area does not support the number of dwelling units, the site must qualify for density bonuses (see Sections 3.200-3.220). **On a separate sheet(s) of paper identify any bonus(es) being requested;** explain how this project qualifies, and submit the percentage for each and recalculated density based upon the bonus(es).

Maximum density for base zone is: _____, regardless of density bonuses (per ADC Section 3.020. Proposed number of units per net acre: _____.

4. **Common Space calculations** [See ADC 8.220 (1) and (2).] Common open space is required for projects of 10 or more units at 0.25 sq.ft. for each 1.0 sq.ft. of living area. Total square feet in living space: _____.

Common space required: _____sq. ft. Common space provided: _____ sq. ft.

Please identify all common areas on the Site Plan and dimensions of each area.

5. **Parking analysis:** Parking spaces must be shown and dimensioned on the site plan. [See Article 9 for design standards.] Note: There are other categories of parking for special uses. If any pertain to this application, list the use(s) and the parking requirement in the following format:

_____ Studio and 1-bedroom units @ 1 space/unit = _____ spaces

_____ 2-bedroom units @ 1.5 spaces/unit = _____ spaces

_____ 3- 4-bedroom units @ 2 spaces/unit = _____ spaces

_____ Total number of units divide by 4 = _____ visitor spaces

Total # of required parking spaces: _____ **Total # space provided on plan:** _____

Number of parking spaces by type: Standard____ Disabled____ Compact____ Garages____

- 6. **Bicycle parking analysis:** Multiple-family developments must provide one bicycle parking space per 4 dwelling units. [See ADC 9.120(13).] Required bicycle parking spaces: _____ # provided: _____
- 7. **Building separation and setbacks:** A 10-foot separation is required between single-story multi-family buildings and 20-foot is required between buildings 2 or more stories. When multi-family developments abut single-family uses or zones, the setback shall be at least 1 foot for each foot of building height. See ADC Section 8.270 for specific standards. Please clearly indicate on the elevation drawings the height, setback of EACH building on the elevation drawings and building separation between each multi-family dwelling building.

SITE PLAN REVIEW – PURPOSE AND PROCEDURE

Site Plan Review is intended to promote functional, safe, and attractive developments compatible with surrounding developments and uses and with the natural environment. It mitigates potential land use conflicts through specific conditions attached by the review body. Site Plan Review is not intended to evaluate the proposed use or structural design. Rather, the review focuses on the layout of a development, including building placement, setbacks, parking areas, external storage areas, open areas, and landscaping.

The Director acts as the review body for a Site Plan Review application. The application is processed under the Type I-L limited land use procedure unless filed with a concurrent application that requires a public hearing. The City sends a written Notice of Filing of the proposed development to owners of property located within 300 feet of the boundary of the proposed development. At the Director's discretion, the notice area may be increased up to 1,000 feet due to land use or transportation patterns or an expected level of public interest.

Notice is also provided to any neighborhood or community organization recognized by the City Council whose boundaries include the subject site and is located within 300 feet of the site. Those notified have 14 days from the date of the Notice of Filing to submit written comments about the proposal to the Planning Division.

Oregon statutes require that land use decisions be made within 120 days from the date the application is deemed complete. However, unless the project is complex, or a large number of applications have been submitted for review, the City typically is able to issue a decision within a shorter time.

The City's decision on projects that did not require a neighborhood meeting may be appealed by filing a Notice of Intent to Appeal to the State Land Use Board of Appeals (LUBA) not later than 21 days after the date of the decision. In order to be able to appeal to LUBA, an affected party must have raised an issue in writing before the date given in the Notice of Filing. The City's decision on projects that required a neighborhood meeting may be appealed to the Planning Commission within 10 days of the Notice of Decision.

EXAMPLE OF FINDINGS OF FACT

CRITERIA FOR FINDINGS OF FACT:

Site Plan Review approval will be granted if the approval authority finds the application conforms with the criteria found in Article 2.450 of the ADC, and to applicable development standards. Before the reviewing authority can approve an application, the applicant must submit information that adequately supports the application. If the applicant submits insufficient or unclear information, the application will be denied or delayed.

FORMAT FOR FINDINGS OF FACT:

Statements addressing individual criteria must be in a “finding of fact” format. A finding of fact consists of two parts:

1. Factual information such as the distance between buildings, the width and type of streets, the particular operating characteristics of a proposed use, etc. Facts should reference their source: on-site inspection, a plot plan, City plans, etc.
2. An explanation of how those facts result in a conclusion supporting the criterion.

EXAMPLE:

Criterion: The design and operating characteristics of the proposed development are reasonably compatible with surrounding development and land uses, and any negative impacts have been sufficiently minimized.

Facts: The area around the site is surrounded by Community Commercial zoning on all four sides. This proposed indoor recreation use will be generally consistent with the operating characteristics of the Community Commercial zone as well as other nearby office and commercial development. A noted exception however is that the facility will be operational 24 hours a day. The only other businesses in the immediate area that serves customers 24 hours a day are two motels to the north and east of the property. There are no residential dwellings in the vicinity of this project. Onsite landscaping meeting requirements of Article 9 will be installed and provided irrigated as shown on the attached plan.

Conclusion: The proposed use will be compatible with the existing uses in the area.