



COMMUNITY DEVELOPMENT

333 Broadalbin Street SW, PO Box 490, Albany, Oregon 97321-0144 | BUILDING 541-917-7553 | PLANNING 541-917-7550

Notice of Decision

Site Plan Review

SP-05-20

May 6, 2020

Application Information

Proposal:	To construct a new 1080 square foot residential accessory structure.
Review Body:	Staff (Type I-L review)
Report Prepared By:	Tony Mills, Planner I
Property Owner/Applicant:	James Cahill; 2220 17th Avenue SW, Albany, OR 97321
Address/Location	2220 17th Avenue SW
Map/Tax Lot:	Linn County Assessor's Map No. 11S-04W-12; Tax Lot 2100
Zoning:	Residential Single-Family (RS-6.5)

On May 6, 2020, the City of Albany Community Development Director granted **Approval with Conditions** of the application referenced above.

The City based its decision on the project's conformance with the review criteria listed in the Albany Development Code (ADC). The supporting documentation relied upon by the City in making this decision is available for review at City Hall, 333 Broadalbin Street SW. For more information, please contact the project planner, **Tony Mills**, at 541-917-7555 or Planning Manager David Martineau at 541-917-7561.

The City's decision may be appealed to the Oregon Land Use Board of Appeals (LUBA) if a person with standing files a Notice of Intent to Appeal not later than 21 days after the Director's Notice of Decision is mailed [ADC 1.330(5)(a)]. The applicants may proceed, at their own risk, prior to the end of the appeal period, provided they sign a Release and Indemnity Agreement with the City.

This approval shall expire three years from the date of approval unless 1) the applicant has installed all of the required public infrastructure related to the development and the infrastructure has been accepted by the City, or 2) the applicant has provided financial assurance for all required public infrastructure per ADC Section 12.600, or 3) the development did not require public infrastructure, a valid building permit exists for new construction or improvements, and work has commenced.

Signature on File

Community Development Director

Appeal Deadline: May 27, 2020

Approval Expiration Date (if not appealed): May 6, 2023

Attachments: Location Map, Site Plan

cd.cityofalbany.net



Conditions of Approval

The issuance of this permit by the City of Albany does not eliminate the need for compliance with other federal, state, or local regulations. It is the applicant's responsibility to contact other federal, state, or local agencies or departments to assure compliance with all applicable regulations.

Condition 1 Prior to final building inspection, the driveway must be paved at least 20 feet back from the existing edge of pavement along the west side of 17th Avenue. The width of the driveway must be between 10 feet and 24 feet at the point of the public right-of-way.

Condition 2 Development shall occur consistent with the plans and narrative submitted by the applicant, or as modified by conditions of approval and shall comply with all applicable state, federal, and local laws.

Information for the Applicant

Please read the following requirements. This list is not meant to be all-inclusive; we have tried to compile requirements that relate to your specific type of development. These requirements are not conditions of the land use decision. They are Albany Municipal Code (AMC) or ADC regulations or administrative policies of the planning, engineering, fire, or building departments that you must meet as part of the development process. You must comply with state, federal, and local law. The issuance of this permit by the City of Albany does not eliminate the need for compliance with other federal, state, or local regulations. It is the applicant's responsibility to contact other federal, state, or local agencies or departments to assure compliance with all applicable regulations.

Planning

1. Land use approval does not constitute building or public works permit approvals.
2. Construction of the development must substantially conform to the approved Site Plan Review.

Building

Permits

3. Obtain building permits prior to any construction.
4. An Erosion Prevention and Sediment Control Permit is required to be obtained from public works before commencing land disturbing activities affecting an area of 2,000 square feet or greater, cumulatively.

Plan Review for Permits

5. All plans submitted for review for building permits will need to be submitted electronically. Contact the Building Division front counter at ePlans@cityofalbany.net for details and instructions prior to submittal.

Public Works - Engineering


The City of Albany's infrastructure records, drawings, and other documents have been gathered over many decades, using differing standards for quality control, documentation, and verification. All information provided represents the current information we have in a readily available format. While the information we provide is generally believed to be accurate, occasionally this information proves to be incorrect, and thus we do not warrant its accuracy. Prior to making any property purchases or other investments based, in full or in part, upon the information provided, we specifically advise that you independently field verify the information contained within our records.

Fire

The fire department has reviewed the above project for conformance to the 2014 Oregon Fire Code and has no comments.

Legend

-  2220 17th Ave SW
-  Albany Parcels



\\con.cityofalbany.net\homas\tronym\Desktop\locationmap\temp\latc.mxd




Date: 3/5/2020 Map Source: City of Albany

2220 17th Ave SW Location / Zoning Map

James Cahill
 2220 17th Ave. SE, Albany OR
 Parcel No. 11S04W12DTax Lot: 2100
 Area: 40,510 sf. (.93 acre)
 Largest extents: 175' N-S, 307' E-W
 Parcel No: 11S04W12 Tax Lot: 2100
 Zone: RS-6.5
 February 22, 2020

Site Plan for Proposed Garage/Shop

Scale: 1 square = 1/4" = 10 ft



Notes:
 No structures need to be demolished.
 No trees are to be removed.
 No sprinkler system

BPA property



Bonnie St.

17th Ave. SW