



NOTES:

1. CONCRETE SHALL HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 4000 PSI.
2. CURB AND GUTTER SHALL BE CONSTRUCTED INDEPENDENTLY, AND SEPARATED BY A COLD JOINT, FROM ALL ADJACENT CONCRETE CONSTRUCTION; INCLUDING SIDEWALKS AND DRIVEWAY RAMPS.
3. PROVIDE CONTRACTION JOINT AT MIDPOINT OF DRIVEWAY IF DRIVEWAY WIDTH IS 16' OR GREATER.
4. RESIDENTIAL DRIVEWAY WIDTH 10' - 24'. COMMERCIAL DRIVEWAY WIDTH PER DEVELOPMENT CODE, ARTICLE 12, CHAPTER 12.100.
5. NEW DRIVEWAY ACCESS CONSTRUCTION IN AN EXISTING CURB SHALL BE CONSTRUCTED WITH THE USE OF HORIZONTAL CONCRETE SAWCUTTING EQUIPMENT. SEE 306.02.07B.

CITY OF ALBANY, OREGON
PUBLIC WORKS DEPARTMENT

DRIVEWAYS ON ROLLED CURB
WITH
CURB SIDE SIDEWALK

NO SCALE

OCTOBER 2013

NO. 309B