



NOTES:

1. CULVERT PIPE SHALL BE TYPE 3 REINFORCED CONCRETE OR CORRUGATED HIGH-DENSITY POLYETHYLENE WITH SMOOTH INTERIOR, ADS N-12 OR APPROVED EQUAL.
2. CULVERT PIPE SHALL BE MIN. DIA. OF 12" OR AS SPECIFIED BY THE CITY OF ALBANY ENGINEERING DEPT.
3. CULVERT ENDS SHALL BE MITERED 2:1 ON PIPE LARGER THAN 15" DIA.
4. ROADSIDE DITCHES SHALL NOT BE FILLED IN EXCEPT AT DRIVEWAY LOCATIONS WITH CULVERT.

CITY OF ALBANY, OREGON
PUBLIC WORKS DEPARTMENT

CULVERT DETAIL
FOR
STANDARD DRIVEWAY APPROACH
UNIMPROVED STREETS

NO SCALE

JANUARY 2018

NO. 312