



NOTES:

1. CULVERT ENDS SHALL BE MITERED 2:1 ON PIPE LARGER THAN 15" DIA.
2. CULVERT PIPE SHALL BE TYPE 3 REINFORCED CONCRETE WITH MIN. DIA. OF 12" OR AS SPECIFIED BY THE CITY OF ALBANY ENGINEERING DEPT.
3. ROADSIDE DITCHES SHALL NOT BE FILLED IN EXCEPT AT DRIVEWAY LOCATIONS WITH CULVERT.

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
CULVERT DETAIL FOR STANDARD DRIVEWAY APPROACH UNIMPROVED STREETS		
NO SCALE	MAY 1998	NO. 312