



NOTES:

1. THIS DETAIL DWG. SHOWS REQUIREMENTS FOR PROVIDING MIN. CLEAR SPACE AROUND EXISTING OBSTRUCTIONS IN NEW AND EXISTING, NON-STANDARD CURBSIDE SIDEWALK. COMMON OBSTRUCTIONS INCLUDE FIRE HYDRANTS, MAIL BOXES, UTILITY POLES, AND OTHER OBJECTS THAT MAY IMPEDE PEDESTRIAN TRAFFIC.
2. W = MINIMUM SIDEWALK WIDTH. SEE DETAIL DWG. NO. 313 FOR MINIMUM SIDEWALK WIDTHS AND CONSTRUCTION SPECIFICATIONS. THE ACTUAL AMOUNT OF CLEAR SPACE BETWEEN THE OBSTRUCTION AND BACK OF THE SIDEWALK SHALL EQUAL THE MINIMUM SIDEWALK WIDTH.
3. FOR UPGRADING EXISTING CURBSIDE SIDEWALK, MIN. LIMITS OF SIDEWALK REPLACEMENT ARE AS SHOWN. CONSTRUCTION OF ADDITIONAL SIDEWALK AGAINST THE BACK OF EXISTING SIDEWALK TO MEET MIN. CLEAR SPACE REQUIREMENTS IS NOT PERMITTED.
4. ADDITIONAL PUBLIC R.O.W. MAY BE REQUIRED TO MEET MINIMUM SIDEWALK WIDTH REQUIREMENTS.
5. THE ENCROACHMENT PERMIT ISSUED FOR A SPECIFIC SITE WILL DETERMINE CONFIGURATION OF SIDEWALK INVOLVING NON-STANDARD DIMENSIONS AND R.O.W. LIMITATIONS.

SECTION A-A

MIN. CLEAR SPACE W
 (6' FOR LOCAL AND
 7' FOR COLLECTOR AND
 ARTERIAL STREETS)

SEE DETAIL DWG. NO. 202
 FOR MAILBOX LOCATION

SHADED AREA DENOTES MINIMUM
 SIDEWALK REPLACEMENT LIMITS
 (FOR UPGRADE OF EXISTING SIDEWALK)

TRANSITION PANELS
 LENGTH = $2 \times W$ MIN.

W

W

W

W

W

MIN. CLEAR SPACE W
 (6' FOR LOCAL AND
 7' FOR COLLECTOR AND
 ARTERIAL STREETS)

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
CONSTRUCTION OF SIDEWALK AROUND EXISTING OBSTRUCTIONS ON CURBSIDE SIDEWALK		
NO SCALE	MAY 1998	NO. 314