



NOTES:

1. SEE DETAIL DWG. NOS. 401 AND 402 FOR ADDITIONAL REQUIREMENTS RELATIVE TO THE CONSTRUCTION OF PRECAST STANDARD AND FLAT-TOP MANHOLES.
2. DROP MANHOLES SHALL BE CONSTRUCTED WHERE THE DISTANCE BETWEEN PIPE INVERTS WILL EXCEED 24" IN SANITARY SEWER MANHOLES.
3. DROP ASSEMBLIES SHALL BE CONSTRUCTED OF MATERIALS APPROVED FOR USE IN SANITARY SEWER SYSTEMS.
4. DROP ASSEMBLIES SHALL BE CONSTRUCTED ON THE OUTSIDE OF THE MANHOLE AS SHOWN. INSIDE DROP ASSEMBLIES ARE NOT PERMITTED WITHOUT THE APPROVAL OF THE CITY ENGINEER.

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
STANDARD DROP MANHOLE		
NO SCALE	MAY 2005	NO. 403