



NOTES:

1. MANHOLE BASES, BARREL SECTIONS, CONES, AND GRADE RINGS SHALL BE CONSTRUCTED OF PRECAST REINFORCED CONCRETE CONFORMING TO ASTM C478.
2. MINIMUM DIAMETER OF THE BASE SECTION SHALL BE 60 INCHES, OR THE LARGEST PIPE DIAMETER + 24 INCHES, WHICHEVER IS GREATER.
3. MANHOLE COMPONENTS SHALL BE SUPPLIED WITH NO LADDER ASSEMBLIES.
4. PIPE OPENINGS SHALL BE CORE DRILLED OR BLOCKED OUT (CIRCULAR OPENINGS ONLY) AT THE TIME OF MANUFACTURE.
5. PIPE CONNECTIONS SHALL BE MADE WITH MANUFACTURED, FLEXIBLE, WATERTIGHT CONNECTORS.

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
LARGE DIAMETER PRECAST MANHOLE FOR PIPE LARGER THAN 24" DIAMETER		
NO SCALE	JANUARY 2015	NO. 408