



NOTES

1. SIDEWALK ELEVATION MUST BE SET ABOVE CHECK DAM AND INLET/OUTLET ELEVATIONS TO ALLOW OVERFLOW TO DRAIN TO STREET OR PIPED OVERFLOW SYSTEM AS APPLICABLE. SIDEWALK ELEVATION TO BE SET AT 1.5% RISE FROM TOP OF FACE OF CURB.
2. ALL PCC SURFACES SHALL BE SMOOTH AND FREE OF DEFECTS AND SHALL HAVE A LIGHT BROOM TEXTURED FINISH.
3. STREETSIDE CURB NOTCHES TO BE LOCATED AS IDENTIFIED ON PROJECT PLANS.
4. ACTUAL ELEVATIONS AND RELATIONSHIPS BETWEEN FEATURES TO BE CONSTRUCTED AS IDENTIFIED ON PROJECT PLANS.
5. GRAVEL SPLASH PAD: INSTALL WASHED ROCK AT EACH CURB NOTCH.
6. CHECK DAMS SHALL BE PLACED ACCORDING TO INDIVIDUAL PROJECT PLANS.
7. SWALE SHALL HAVE A FLAT BOTTOM IN ALL DIRECTIONS TO WITHIN A HALF INCH.

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
STREETSIDE SHALLOW SWALE PLAN VIEW		
NO SCALE	JANUARY 2015	NO. 603A