



NOTES

1. ALL PCC SURFACES SHALL BE SMOOTH AND FREE OF DEFECTS AND SHALL HAVE A LIGHT BROOM TEXTURED FINISH.
2. PLANTER WALLS EXCEEDING 40 FEET IN LENGTH REQUIRE SPECIAL DESIGN CONSIDERATION FOR A KEYED JOINT.
3. PLACE A CONTRACTION JOINT IN THE FACE OF THE WALL AT EACH SIDEWALK DRAINAGE NOTCH. CONTRACTION JOINTS SHALL BE PLACED IN LINE WITH ONE OF THE DRAINAGE NOTCH CORNERS.
4. CONTRACTION JOINT SPACING SHALL NOT EXCEED 10 FEET REGARDLESS OF LOCATION OF DRAINAGE NOTCH.
5. SIDEWALK ELEVATION MUST BE SET ABOVE STREET INLET/OUTLET ELEVATIONS TO ALLOW OVERFLOW TO DRAIN TO STREET OR PIPED OVERFLOW SYSTEM AS APPLICABLE.

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
PLANTER WALL		
NO SCALE	JANUARY 2015	NO. 609