



NOTES

1. LUMBER TO BE A NATURALLY ROT-RESISTANT WOOD (E.G. CEDAR, ETC.). MANUFACTURED PRODUCTS CAN BE USED WITH APPROVAL. NO CHEMICALLY TREATED WOOD WILL BE ALLOWED.
2. ALL FASTENERS TO BE STAINLESS STEEL OR ALUMINUM.
3. 4" X 4" X 18" ANGLE BRACKET TO BE MADE OF MIN. 3/16" STAINLESS STEEL, OR ALUMINUM.
4. TOP OF BRACKET TO BE NO HIGHER THAN TOP OF CHECK DAM.
5. MIN. 3 BOLTS TO CONCRETE, MIN. 2 BOLTS PER BOARD. USE 5/16" DIA. BOLTS.
6. FOR LINED FACILITIES USE, COLUMN DETAIL FROM DWG. 618 FOR STREET CURB SIDE.

<p>CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT</p>		
<p>WOOD CHECK DAM FOR PLANTER</p>		
<p>NO SCALE</p>	<p>JANUARY 2015</p>	<p>NO. 619</p>